



# Long Beach Fire Department Bureau of Fire Prevention

**OPERATIONAL FIRE PERMIT**  
NO. 2.038 9/08

## RELATED TO CARNIVALS

Name \_\_\_\_\_ Phone (\_\_\_\_) \_\_\_\_\_  
Address \_\_\_\_\_ Fax (\_\_\_\_) \_\_\_\_\_  
City \_\_\_\_\_ State \_\_\_\_\_ Zip Code \_\_\_\_\_

### IMPORTANT:

The Carnival Ride Operator shall be in complete compliance with the State of California Division of Occupational Safety and Health's Elevator Ride Unit. Each ride must have a current State tag attached.

Event Description \_\_\_\_\_  
\_\_\_\_\_

Event Location \_\_\_\_\_

Event Date(s) \_\_\_\_\_ Estimated Daily Attendance \_\_\_\_\_

Event Time(s) Start \_\_\_\_\_ am/pm Finish \_\_\_\_\_ am/pm

1. A plot plan showing location of all A plan of the carnival set up shall be submitted to Fire Prevention for approval showing all rides, booths, games, aisles, toilet facilities, fences, cooking areas, generators, fuel storage, and any other structures. Plan shall include dimensions and distances to all public ways and the nearest buildings on all sides. etc., must be submitted to the Bureau of Fire Prevention for approval **10 days prior to the event**.
2. All aisles and exitways shall be a minimum of 44 inches, smoothly graded, and free of pot holes, hoses, wiring, or any other trip hazards or obstructions.
3. Public access must be prevented within 4 feet of any moving part of a slow moving (kiddie) ride and within 6 feet of any moving part of a fast moving (adult) ride.
4. Approved fire extinguishers of type 2A 10BC must be readily available and not more than 75 feet travel distance from any event location.
5. All cooking appliances must be UL approved. Cooking appliances producing grease laden vapors shall be protected by a hood and automatic hood extinguishing system. An approved 40BC fire extinguisher shall also be available at cooking location.

6. Cooking booths or areas shall have minimum clearances of 10 feet on two sides and shall not be located within 10 feet of amusement rides or devices.
7. An unobstructed 20 foot wide access road acceptable for fire apparatus use must come within 150 feet of all event areas.
8. Flammable and combustible liquids shall be stored in portable tanks and containers in accordance with CFC Chapter 34.
9. Emergency access for fire equipment must be provided.
10. Stand-by Fire Safety Officer for the event may be required at the discretion of the Fire Marshal.

\*\*\*\*\*

**For Dept. Use Only**

Date application received \_\_\_\_\_ Amount Paid \_\_\_\_\_

Approved  Denied By: Captain/Inspector \_\_\_\_\_

Remarks: \_\_\_\_\_